

Gas Heater Type A Appliance Service Report

Date:			
Licensed/Registered person:		Licence/Registration no:	
Client name:		Contact no:	
Street address:			
Suburb:		Postcode:	
Appliance:		Certified?	
Manufacturer:	Model:	Serial no:	
Date of installation:		Compliance Certificate no:	

General installation observations:	
------------------------------------	--

Appliance condition:	
----------------------	--

Fluing system condition: (including chimney)	
---	--

Approved cowl:	If no, action taken:	
Is room ventilation compliant?	If no, action taken:	
Appliance isolation valves:		
Appliance electrically safe:		

Negative pressure test — as per ESV / VBA's Negative Pressure and Carbon Monoxide Spillage Test Report (if applicable)

Result:								
Clean dust and debris from:	Appliance	Burner	Pilot		Fan	Filters	Air intakes	
Cracked heater exchanger:								

Note: If a heat exchanger is cracked or split, any immediate danger can be determined by a combustion spillage test.

Check and set appliance operating pressure:	kPa					
Gas burner check:	Burner ignition	Flame abnormality		Flame impingement		
Check operation of appliance and safety devices:						

Carbon Monoxide Spillage Test Report provided:	
Repairs:	

Statement of compliance

Heater cleaned and serviced:	Heater isolated due to CO spillage or fault:	
Next service date:	Client's signature:	

Note: If heater is immediately unsafe and client refuses to have the heater isolated — notify ESV on 1800 652 563, select option 5.

This Report should be completed in conjunction with the Carbon Monoxide Spillage Test Report and a copy should be provided to your client at the completion of the service. This is not a comprehensive list of service and maintenance activities for all appliances and should be used as a minimum to ensure the appliance safety. It should be used in conjunction with AS 4575 Gas appliance - Servicing of Type A appliances.